

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 23.06.2025

It is certified that an inspection team headed by ..M..S....Narendiran (Junior water Analyst)

(Name of Officers with designation) from District Water Testing Lab...PHED TWAD Board.

inspected theS.R.E.E.....A.B.I.I.R.A.M.I.(C.B.S.E.)..SCHOOL.....

(Name & Address of the school) on 23.06.2025...(date of inspection) and on the basis of Water Test Report (Attached) bearing no..6.7.2.11-6.7.2.11.A/JanA/2023 dated...23.06.2025

of .District....level....water..... (PHED Lab) certified that theTesting.....laboratory.....V.E.I.I.R.E....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid tillone....year.....

M.S.Narendiran

Junior Water Analyst
TWAD Board

Signature with Seal:Vellore - 632 004.....
Name : M.S. Narendiran
Designation : Junior Water Analyst
Name & Address of the Office / Department :

To Sree...Abirami...SCHOOL...
K.K.E.I.I.R.E.....Gudiyathiram
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



TEST WATER BEFORE TASTE

twadlabphotos@gmail.com
Ph : 0416 - 2215168

TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
District Level Water Testing Laboratory
Opp. To Muthu Mandapam, Old Katpadi Road, Vellore - 632 004.

TEST REPORT

TO:
SREE ABIRAAMI (CBSE) SCHOOL,
Katpadi Main Road,
Keelalathur,
Gudiyatham Taluk.635 803

Lr.No.67211-67211A/JWA/Lab/VLR/2025/dt:27.06.2025.

Sir,

Ref : Lr.No: Dated. 24.06.2025

2.T.O Invoice No: 11423,Dated:24.06.2025. For Rs: 1652/-

The result of analysis for the water samples sent under reference is enclosed

Scheme: PVT

Date of Collection: 24.06.2025.

Source :Drinking Water

Date of Receipt : 24.06.2025.

Location:67211/67211A: School Entrance,Sree Abiraami (CBSE) School,Keelalathur.

BIS 10500:2012	Acceptable Limit	Maximum permissible limit in the absence of alternative source.	Result
I.PHYSICAL EXAMINATIONS			
1. Appearance			67211
2. Colour			Clear
3. Odour	Agreeable	Agreeable	None
4. Turbidity NTU	1	5	0
5. Total dissolved solids mg/L	500	2000	120
6. Electrical conductivity micro mho/cm		-	172
II.CHEMICAL EXAMINATIONS			
7. pH	6.5-8.5	6.5-8.5	6.75
8. Alkalinity Ph as CaCO ₃ mg/L			0
9. Alkalinity Total as CaCO ₃ mg/L	200	600	40
10. Total Hardness as CaCO ₃ mg/L	200	600	70
11. Calcium as Ca mg/L	75	200	14
12. Magnesium as Mg/L	30	100	9
13. Sodium as Na mg/L	-	-	-
14. Potassium as K mg/L	-	-	-
15. Iron Total as Fe mg/L	0.3	1.0	0.00
16. Manganese as Mn mg/L	0.1	0.3	0.00
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0.00
18. Nitrite as NO ₂ mg/L	-	-	0.00
19. Nitrate as NO ₃ mg/L	45	45	4
20. Chloride as Cl mg/L	250	1000	25
21. Fluoride as F mg/L	1.0	1.5	0.0
22. Sulphate as SO ₄ mg/L	200	400	14
23. Phosphate as PO ₄ mg/L	-	-	0.00
24. Tidys Test 4Hrs.as O ₂ mg/L	-	-	0.0
III. BACTERIOLOGICAL EXAMINATION (M.F.Technique)			
Fecal Coliform(100ml)	-	-	0

Report:67211: The water sample is chemically Potable.

Report:67211A: The water sample is Bacteriologically Not contaminated.

67211A
 Junior Water Analyst 27/6/25
 TWAD Board
 District Water Testing Laboratory
 Vellore - 632 004.



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant

Certificate Number : TN00125VLR18314

Issued Date : 13-12-2025

Organization Type : Educational Institutions

Expiry Date : 12-12-2026

Name of the Organization : SREE ABIRAAMI SCHOOL

Address : S.F.No.6/3, 6/4, 7/1,9/1 & 9/12 , Gudiyatham - Katpadi Main

Road, Kilalathur, K.V.Kuppam Taluk, Vellore District - 635803

I, JOTHIRAM K owner/manager of the SREE ABIRAAMI SCHOOL functioning as Educational Institutions located at

Kilalathur in Vellore district hereby declare that

- This Self-Declared Sanitation certificate is valid from **13-12-2025** to **12-12-2026** and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate **310** people/pupils and has **22** urinals and **24** toilets which is proportionate to the number of users as per government norms.
- 3** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.



Signature of the Owner/Manager



(அ) TN00125VLR18314 என்ற தனிப்பாட்ட சான்றிதழ் எண்ணை

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(ஆல்லது)

(ஆ) கைப்பேசியில் பார்க்காடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00125VLR18314 in the URL

<https://www.tnsevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.